CERTIFICATE

Issued to: Applicant: ABB Stotz-Kontakt GmbH Eppelheimer Str. 82 69123 Heidelberg, Germany

Licensee: ABB Stotz-Kontakt GmbH Eppelheimer Str. 82

69123 Heidelberg, Germany

Product:Switch-disconnectorTrade name(s):AEGType(s)/model(s):ESDxx series

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to EN IEC 60947-3:2021
- an inspection of the factory location according to CENELEC Operational Document/CIG 021
- a DEKRA certification agreement with the number 900400

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 11 December 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-133643

DEKRA Certification B.V.

B.T.M. Holtus Managing Director

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL

H.R.M. Barends Certification Manager



DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra.nl Company registration 09085396



ANNEX TO KEMA-KEUR CERTIFICATE 71-133643

SPECIFICATION OF THE CERTIFIED PRODUCT

| Product data Product Trade name(s) Type(s)/model(s) Method of operation Suitability for isolation Number of positions of the main contacts Rated insulation voltage (Ui) Rated impulse withstand voltage (Uimp) Rated operational current (le) Conditional free air thermal current Rated uninterrupted current (lu) Rated conditional short-circuit current | Switch-disconnector AEG ESD10x, ESD20x, ESD30x and ESD40x independent manual operation suitable 2 (ON and OFF) 440 V 4 kV 40 A, 63 A 40 A, 63 A 40 A, 63 A 10 kA |
|---|---|
| Product data – type ESD10x Number of poles Kind of current Rated operational voltage (Ue) Rated frequency Utilization category Kind of protective device for AC application Kind of protective device for DC application | 1 pole AC and DC 240 Vac 60 Vdc 50 / 60 Hz or DC AC-22A DC-21A Fuse, NH, size 00, gG Cut-off current to a maximum of 4,8 kA Joule integral (l²t) to a maximum of 11,9 kA²s Fuse, D, size 02, gG Cut-off current to a maximum of 2,2 kA Joule integral (l²t) to a maximum of 14,0 kA²s |
| Product data – type ESD20x Number of poles Kind of current Rated operational voltage (Ue) Rated frequency Utilization category Kind of protective device for AC application Kind of protective device for DC application | 2 poles AC and DC 415 Vac 125 Vdc 50 / 60 Hz or DC AC-22A DC-21A Fuse, NH, size 00, gG Cut-off current to a maximum of 4,81 kA Joule integral (l²t) to a maximum of 16,0 kA²s Fuse, D, size 02, gG Cut-off current to a maximum of 3,04 kA Joule integral (l²t) to a maximum of 14,0 kA²s |
| Product data – type ESD30x Number of poles Kind of current Rated operational voltage (Ue) Rated frequency Utilization category | : 3 poles : AC : 415 Vac : 50 / 60 Hz : AC-22A |

page 1 of 2



ANNEX TO KEMA-KEUR CERTIFICATE 71-133643

page 2 of 2

Kind of protective device : Fuse, NH, size 000, gG Cut-off current to a maximum of 4,45 kA Joule integral (I²t) to a maximum of 18,5 kA²s

Product data – type ESD40x

Number of poles Kind of current Rated operational voltage (Ue) Rated frequency Utilization category Kind of protective device 4 poles
AC
415 Vac
50 / 60 Hz
AC-22A
Fuse, NH, size 000, gG
Cut-off current to a maximum of 4,45 kA
Joule integral (l²t) to a maximum of 18,5 kA²s

TESTS

Test requirements

EN IEC 60947-3:2021

Test result

The test results are laid down in DEKRA test file 228124700.

Additional information

This certificate is based on certificate No. 71-133642.

Type designation of ESDxx: for example ESD4063

The first x denotes the number of phase poles, it can be 10 for 1-Pole 20 for 2-Pole 30 for 3-Pole 40 for 4-Pole

The second x denotes the rated operational current, it can be 40 for 40 A 63 for 63 A

Conclusion

The examination proved that all requirements were met.

Factory location

ABB Bulgaria EOOD Rakovski Branch Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski industrial zone, 14 Industrial Road 1 4142 Rakovski, Bulgaria